

Village of Barker



PUBLIC WORKS REPORT January 2019

Mark Remington, Superintendent
Gene Cavanaugh
Robert Verheyen

STREETS:

- ✓ Went around with tractor-picked up brush
- ✓ Plowed & salted streets, Village Hall parking lot & East Ave Extension to Police Building, also shoveled walkways & steps of the Village Hall and Library
- ✓ Pushed snow piles back and cleared storm drains
- ✓ Called Paul Alvers, NC sign department, he made custom signage to help indicate where the new Village Hall is located (both for the Village Hall & Police Department)

WATER:

- ✓ Dig request at 1726 Quaker Road, the catholic church, located and marked service to church and water main
- ✓ 8713 Main Street-received a call that water meter was leaking, went and repaired the meter
- ✓ Harold Niethe-1890 Pallister Avenue, called to indicate his water pressure was high-Drum Oil replaced his expansion tank on the hot water tank-checked water pressure with a gauge read about 48 pounds-was normal –also called Dave Branch at NC Water, he sent someone down to check the meter pit-high pressure was caused by expansion tank releasing, which can increase water pressure up to 100lbs.

EQUIPMENT:

- ✓ Went to Drum Oil and picked up a new gauge for gasoline tank at the garage
- ✓ Washed trucks and tractors
- ✓ Broken axle on Dump Truck-picked up parts at NAPA in Newfane and took to Bad Monkeys for repair

PARKS:

- ✓ Took lights and decorations down from the gazebo and bushes
- ✓ Took tree down, packed up lights and decorations, stored them away in the metal building
- ✓ Emptied garbage cans in both parks
- ✓ Picked up branches in both parks
- ✓ Shoveled skating rink and added more water

OTHER:

- ✓ Took garland and lights off of the railing at the Village Hall
- ✓ Filled pot holes at garage area with stone
- ✓ Cleaned up garage parking lot, stone that was plowed in piles
- ✓ Went to Standish & Jones for supplies