

Public Works Report

July 2015

Mark Remington, Superintendent

Gene Cavanaugh

Matt Smolinsky

Streets:

- ✓ Watered plants – Main St., Village Hall and Parks
- ✓ Mowed roadsides, ditches, Village Hall, garage area and East Ave. property.
- ✓ Weeded ditches along Quaker Rd and Coleman Rd.
- ✓ Maintained dump truck and chipper and chipped brush
- ✓ Prepared East Ave. for paving. – picked up loose gravel and payment.
- ✓ County completed paving on Coleman Rd., East Ave and a section of Main St. – Great job!!!
- ✓ Went along with dump truck and trimmed low branches on the sides of all the village roads.
- ✓ Replaced stop sign at Quaker Rd. and Woodward Rd.
- ✓ Replaced stop sign post at East Ave. and Coleman Rd.
- ✓ Blocked off East Ave. between Coleman Rd and High St. until black top cooled down. Reopened later in the day.
- ✓ Went to Shelby Stone and picked up crusher run. Filled edges of East Ave and High St. to protect the edges of the new pavement.

Water:

- ✓ Called for stake out – Main St. and East Ave corner for Leak detection
- ✓ Checked for back flow device at 1872 Pallister Ave for closing on the house.
- ✓ Checked for back flow device at 8703 Coleman Rd.
- ✓ Hooked up outside reader for water at police building and the Key Bank building

Parks

- ✓ Mowed and weeded both parks
- ✓ Emptied garbage cans weekly in both parks
- ✓ Replaced broken rail on fence and stained at the Lake Park.

Other:

- ✓ Wrote monthly report
- ✓ Attended board meeting
- ✓ Attended work session
- ✓ Weeded and sprayed for weeds around police building, trees on village property and Mayer Brothers.
- ✓ Set up for work program that painted the Village Hall. Total of 5 days. Great job was done by the crew.
- ✓ Installed new door knob on Board room door.
- ✓ Filled in ruts from truck that cut down trees at garage. Then placed dirt and seeded.
- ✓ Cleaned up on west side of metal building
- ✓ Checked outside lights at police building. Breaker kept tripping. Called Gerling electrical. Found the problem was with a bare wire inside of light post.
- ✓ Swept and cleaned up debris on garage flat roof.

- ✓ Gave concrete bumpers and village hall there second coat of paint.
- ✓ Obtained protective wrap from Irr Supply and installed on sink drain and supply lines in Library bathroom, which is our handicapped bathroom.
- ✓ Worked on police building – Caulking and re-nailed loose boards
- ✓ Went to Standish & Jones for supplies.
- ✓ Replaced gutter down spout and elbows on village hall